



CALENDAR YEAR 2010 WATER SUPPLY # 3092000

TOWN OF ESSEX WATER DEPARTMENT
44 CENTENNIAL GROVE ROAD, ESSEX, MA 01929

FOR MORE INFORMATION CONTACT MICHAEL GALLI, CHIEF OPERATOR
PHONE (978)-768-6431, FAX (978)-768-2500
E-MAIL mgalli@essexma.org ONLINE: <http://www.essexma.org>

THE DEPARTMENT OF PUBLIC WORKS COMMISSIONERS MEET AT THE ESSEX WATER
FILTRATION PLANT ON THE FIRST AND THIRD MONDAYS OF EACH MONTH AT 7:00 PM

The Town of Essex' water is supplied by three gravel packed wells, one on Centennial
Grove Road and two on Harry Homans Drive. All of the water is treated at the
Essex Water Filtration Plant at 44 Centennial Grove Road.

Essex' water supply is protected by an Overlay Protection Zone
which is enforced by the Essex Board of Health.

The Town of Essex has been granted monitoring waivers for Synthetic Organic Compounds (SOC's)
and Inorganic Compounds (IOC's) due to the consistent quality of the results of our sampling.
No detects have been found in previous monitoring.

**The Essex Water Department was not in violation of
DEP/EPA requirements for this time period.**

Definitions:

Maximum Contamination Level Goal (MCLG): The level of a contaminant in drinking water
below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contamination Level (MCL): The highest level of a contaminant that is allowed in drinking
water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers
Treatment or other requirements, which a water system must follow.

90th Percentile: Out of every 10 homes, 9 were below this level.

Secondary Maximum Contaminant Level (SMCL) These standards are developed to protect the
aesthetic qualities of drinking water and are not health based

EPA: United States Environmental Protection Agency

DEP: Massachusetts Department of Environmental Protection

Health information:

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791

Lead and Copper

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Essex Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

Sodium

Is a naturally occurring common element found in soil and water. It is necessary for the normal functioning of regulating fluids in the human systems. Some people, however, have difficulty regulating fluid volume as a result of several diseases, including congestive heart failure, kidney failure and hypertension. The guideline of 20mg/L for sodium represents a level in water that physicians and sodium sensitive individuals should be aware of in cases where sodium exposures are being carefully controlled. For additional information, contact your health care provider, your local board of health or the Massachusetts Department of Public Health, Bureau of Environmental Health Assessment at (617) 624-5757

For level of detected contaminants see attached Appendix A

Treatment information:

The Town of Essex has been fluoridating its drinking water since the early 1950's and continues this practice following EPA/DEP/DPH guidelines. From 1985 to present, the Essex Water Department has received numerous awards from the Massachusetts Dental Society for outstanding efforts in providing Community Water Fluoridation.

In 1982, the Essex Water Filtration Plant went online to mitigate iron, manganese, taste and odor problems. These items are controlled, the water is then disinfected with chlorine, and the PH adjusted to prevent corrosion in the system. The pH adjustment has helped to control lead and copper leaching from plumbing systems.

Certification:

I Michael Galli, hereby certify and attest that the information contained in this annual Consumer Confidence Report is accurate and correct to the best of my knowledge. I further certify that I have either made this Consumer Confidence Report available for public inspection or have distributed copies to all users of the Essex Water system in accordance with 40 CFR.141-142. Any intentional deception or misinformation represented in this report may be cited as a violation of State and U.S. EPA National Primary Drinking Water Rules.

Signed Michael G. Galli:  Dated: 5/4/2011

THIS REPORT IS A REQUIREMENT OF THE EPA/DEP

Sources of Drinking Water:

Sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases radioactive material and can pick up substances resulting from the presence of animals or human activity.

Contaminants in Source Water

Microbial Contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic Contaminants, such as salts and metals can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining and farming.

Pesticides and Herbicides, may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants, include synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants, can be naturally-occurring or be the result of oil and gas production and mining activities.

Contact EPA's Safe Drinking Water Hotline for more information about contaminants and potential health effects; and EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants: (800) 426-4791

EPA and FDA Regulations:

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water that must provide the same protection for public health

Backflow/Cross Connections

If you have any questions refer to web site: <http://www.mass.gov/dep/water/drinking/xconn.htm>

APPENDIX A

	MCLG	MCL	Highest Level Detected	Date Tested	Violation	Likely Source of Contamination
Copper	1.3ppm	1.3ppm	0.97ppm	7/25/2008	No	Corrosion of household plumbing systems. Erosion of natural deposits. Leaching from wood preservatives. No site exceeded the action level.
90th percentile			0.95			
Lead	0	15ppb	3ppb	7/25/2008	No	Corrosion of household plumbing systems. Erosion of natural deposits. No site exceeded the action level.
90th percentile			0.003			

Tap water samples were collected from 10 sample sites throughout the community

Regulated Contaminant

Total Trihalomethanes [TTHM'S]	0	80ppb	35ppb	8/12/2010	No	By-product of drinking water chlorination
Haloacetic Acids	0	60ppb	9.5ppb	8/12/2010	No	By-product of drinking water chlorination
Chlorine (Total)	4ppm	4ppm	0.77ppm	3/25/2010	No	Water additive used to control microbes
Fluoride	4ppm	4ppm	1.21ppm	6/8/2010	No	Water additive which promotes strong teeth. Erosion of natural deposits. Discharge from fertilizer and aluminum factories.
Nitrate	10ppm	10ppm	0.19ppm	5/20/2010	No	Runoff from fertilizer use. Leaching from septic tanks, sewage. Erosion of natural deposits.
Radionuclide Radium - 228	5pCi/L	5pCi/L	0.6 pCi/L	4/12/2003	No	Erosion of natural deposits.
Turbidity (NTU)	NA	TT	0.52ppm	12/2/2010	No	Soil runoff
Perchlorate	NA	2.0	ND	10/18/2008	No	Rocket propellents, fireworks, munitions, flares and blasting agents

Secondary

Iron (Total)	NA	0.3ppm	0.11ppm	10/11/2010	NA	Natural sources, road salt, by-product of treatment process. No exceedance
Manganese (Total)	NA	0.05ppm	0.13ppm	12/3/2010	NA	Leaching from natural deposits. Yes exceedance
Sodium	NA	NA	0.22ppm	7/14/2009		Erosion of natural deposits and road salt.

Unregulated Contaminant

	NA	NA	2.0ppb	5/21/2010	NA	No high/low range
Chloroform	NA	NA	2.0ppb	5/21/2010	NA	Sample annually - By-product of drinking water disinfection
Bromodichloromethane	NA	NA	3.7ppb	5/21/2010	NA	Sample annually - By-product of drinking water disinfection
Chlorodibromomethane	NA	NA	3.1ppb	5/21/2010	NA	Sample annually - By-product of drinking water disinfection

ppm = parts per million or milligrams per liter (mg/l)

ppb = parts per billion or micrograms per liter (ug/L)

pCi/L = picocuries per liter (measure of radioactivity)

TT = treatment technique - A required process intended to reduce the level of a contaminant in drinking water

ND = no detection

NTU = (nephelometric turbidity units) measurement of clarity, or turbidity of water

NA = not applicable